

AGOSTO 2009

<i>Data</i>	<i>Portata aria ingresso Biofiltro (Nm³/h)</i>	<i>Temperatura aria uscita Biofiltro (°C)</i>	<i>Umidità aria uscita Biofiltro (%)</i>	<i>Δp Biofiltro - Scrubber A (mmH₂O)</i>	<i>Δp Biofiltro - Scrubber B (mmH₂O)</i>	<i>Depressione a monte Scrubber A (mmH₂O)</i>	<i>Depressione a monte Scrubber B (mmH₂O)</i>	<i>Note</i>
14/08/2009	212064	32.6	81	36	41	120	100	
17/08/2009	223134	32.5	78	35	42	114	114	
18/08/2009	226643	33.3	83	39	44	112	112	
19/08/2009	226399	33.0	79	40	44	112	112	
20/08/2009	220353	33.0	75	40	45	114	114	
21/08/2009	210439	32.1	82	40	45	114	114	
22/08/2009	214667	32.3	85	40	44	114	114	
24/08/2009	199179	32.6	73	39	44	114	112	
25/08/2009	194078	33.2	75	39	44	112	110	
26/08/2009	191421	33.6	78	39	45	112	110	
27/08/2009	191069	33.4	81	40	44	112	110	
28/08/2009	202592	33.4	79	39	44	112	110	
29/08/2009	205250	33.2	79	40	44	112	110	
31/08/2009	214977	31.8	79	40	44	112	110	