

SETTEMBRE 2009

<i>Data</i>	<i>Portata aria ingresso Biofiltro (Nm³/h)</i>	<i>Temperatura aria uscita Biofiltro (°C)</i>	<i>Umidità aria uscita Biofiltro (%)</i>	<i>Δp Biofiltro - Scrubber A (mmH₂O)</i>	<i>Δp Biofiltro - Scrubber B (mmH₂O)</i>	<i>Depressione a monte Scrubber A (mmH₂O)</i>	<i>Depressione a monte Scrubber B (mmH₂O)</i>	<i>Note</i>
01/09/2009	211991	32.3	73	40	44	112	110	
02/09/2009	207246	32.8	76	40	44	112	110	
03/09/2009	204879	33.0	79	40	44	114	110	
04/09/2009	201881	31.1	81	40	44	112	110	
05/09/2009	200950	31.3	84	40	44	114	110	
07/09/2009	197717	29.2	67	41	45	114	110	
08/09/2009	203293	27.9	72	41	45	116	110	
09/09/2009	207552	28.4	71	41	45	114	112	
10/09/2009	204381	28.2	74	41	45	116	110	
11/09/2009	202100	28.0	79	41	45	112	110	
12/09/2009	201916	28.6	77	41	45	112	110	
13/09/2009	202044	27.6	80	41	45	112	110	
14/09/2009	197401	25.0	89	40	45	112	110	
15/09/2009	208976	26.0	94	43	46	110	110	
16/09/2009	191697	26.1	95	39	43	110	110	
17/09/2009	194484	26.9	98	39	42	110	110	
18/09/2009	197156	27.3	91	42	46	100	110	
19/09/2009	199319	28.2	88	40	44	110	108	
20/09/2009	190549	27.3	89	39	43	110	110	
21/09/2009	199435	28.0	91	39	44	110	110	
22/09/2009	222489	29.0	86	39	43	80	108	
23/09/2009	230123	28.1	87	40	44	80	108	
24/09/2009	233810	28.2	83	39	44	94	102	
25/09/2009	224051	28.3	80	40	44	92	100	
26/09/2009	220845	29.2	78	40	43	94	102	
27/09/2009	217577	28.3	78	40	44	94	102	
28/09/2009	215494	29.1	79	40	44	94	100	
29/09/2009	211722	27.9	85	41	45	94	100	
30/09/2009	225441	27.8	89	40	45	94	100	