

AGOSTO 2010

Data	Portata aria ingresso Biofiltro (Nm ³ /h)	Temperatura aria uscita Biofiltro (°C)	Umidità aria uscita Biofiltro (%)	Δp Biofiltro - Scrubber A (mmH ₂ O)	Δp Biofiltro - Scrubber B (mmH ₂ O)	Depressione a monte Scrubber A (mmH ₂ O)	Depressione a monte Scrubber B (mmH ₂ O)	Note
01/08/2010	200543	29.3	90	42	44	90	120	
02/08/2010	198947	29.9	90	42	44	90	120	
03/08/2010	223523	29.4	90	43	44	90	120	
04/08/2010	223771	29.9	90	44	44	90	120	
05/08/2010	210326	27.6	90	44	44	90	120	
06/08/2010	209313	27.5	90	47	47	90	120	
07/08/2010	207175	28.6	90	46	47	90	120	
08/08/2010	207094	28.3	90	46	46	90	120	
09/08/2010	204326	28.4	90	46	47	90	120	
10/08/2010	205018	29.9	90	45	46	90	120	
11/08/2010	219616	30.1	90	45	46	90	120	
12/08/2010	224534	30.1	90	44	46	90	120	
13/08/2010	223640	28.8	90	45	46	90	120	
14/08/2010	223801	26.6	90	45	43	90	120	
15/08/2010	225412	27.4	90	47	45	90	120	
16/08/2010	221286	27.2	90	46	46	90	120	
17/08/2010	220341	28.4	90	46	46	90	120	
18/08/2010	214891	28.6	90	45	46	90	120	
19/08/2010	208426	30.9	90	45	45	90	120	
20/08/2010	201526	32.1	90	44	45	90	120	
21/08/2010	205460	31.2	90	43	44	90	120	
22/08/2010	198543	31.7	90	44	44	90	120	
23/08/2010	194023	32.3	90	43	44	90	120	
24/08/2010	207071	32.0	90	44	44	90	120	
25/08/2010	213726	32.1	90	44	44	90	120	
26/08/2010	209655	33.0	90	44	45	90	118	
27/08/2010	192358	33.4	90	43	44	90	116	
28/08/2010	205237	33.7	90	42	43	90	116	
29/08/2010	200622	31.4	90	42	43	90	116	
30/08/2010	198169	31.2	90	42	43	90	116	
31/08/2010	195303	29.2	90	43	43	90	116	